

**WATER QUALITY/ CONSUMER CONFIDENCE REPORT**  
**For**  
**MERRILL WATER DEPARTMENT**  
**FOR THE YEAR 2022**

We are pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We are committed to complying with the Oregon Health Division requirements to supply the Merrill Water Department users with safe drinking water.

**General Water System Information:**

Public Water System: MERRILL WATER DEPT

Public Water System ID#: OR 41-00518

Phone Number: (541) 798-5808

Contact Person: Greg Matthews

Number of Connections: 435

Source Water Assessment: Yes

**Source Information:**

The water system draws its drinking water from groundwater at an onsite well. A source water assessment, per EPA requirements, has been compiled by the State Drinking Water Program. Merrill Water Department is also regulated by the US Public Health Department. It contains detailed information about the water system's source, including potential sources of contamination. The source water assessment may be available for review upon request. If you have any questions about this report or concerning your water quality, please contact Merrill Water Department.

Merrill Water Department, routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022. As water travels over the land or underground, it can pick up substances, or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least some small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we have provided the following definitions:

*Non-Detects (ND)* = Laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* = One part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* = One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Parts per trillion (ppt) or Nanograms per liter (nanograms/l)* = One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

*Parts per quadrillion(ppq) or Picograms per liter(pictograms/l)* = One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

*Picocuries per liter (pCi/L)* = Picocuries per liter is a measure of the radioactivity in water.

*Millirems per year (mrem/yr)* = Measure of radiation absorbed by the body.

*Million fibers per Liter (MFL)* = Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

*Nephelometric Turbidity Unit (NTU)* = Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Variances & Exemptions (V&E)* = State or EPA permission not to meet an MCL or a treatment technique under certain conditions. **(Only systems with a variance or exemption are REQUIRED to include this definition. In addition, it is REQUIRED to provide an explanation of the reasons for the variance or exemption, date issued, status or remediation.)**

*Action Level* = The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment technique (TT)* = A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level (MCL)* = The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant level Goal (MCLG)* = The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* = The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)*= The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

## TEST RESULTS

Contaminant	MCLG	MCL	Likely Source of Contamination
Coliform bacteria	0	5% of Monthly Samples	Naturally present in the environment

Coliform bacteria is an indicator organism if found in drinking water that could mean something potentially harmful is in the water. Coliform bacteria are found in nature. Fecal Coliform bacteria are associated with septic and/or animal waste contamination and can cause intestinal problems and health concerns if detected and not treated.

Nitrates are tested annually for all water systems as they are a breakdown of pesticides and fertilizers and are a health risk for young infants, pregnant or nursing women.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS, or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline: (800) 426-4791.

Lead is tested every three years for all water systems. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Merrill Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the

potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

#### Chemical Monitoring Results:

<u>Contaminant</u>	<u>Testing Date</u>	<u>Level Detected</u>	<u>MCL</u>	<u>Most Likely Source of Contamination</u>
Nitrates	3/9/22	1.03 mg/l	10.0 mg/l	Pesticides and Fertilizers
Lead	9/9/21	0.0005 mg/l	0.015 mg/l	Corrosion of household plumbing systems; natural deposits
Copper	9/9/21	0.0054 mg/l	1.30 mg/l	Corrosion of household plumbing systems; natural deposits
Inorganic Compounds	11/16/21	See Attached List		Pesticides, fertilizers and naturally occurring in the groundwater or soil from erosion
Volatile Organics	11/8/22	See Attached List		Gasoline & gasoline additives
Synthetic Organics	11/8/22	See Attached List		Pesticides, herbicides, insecticides, & fertilizers
Combined Radium 228/226	3/9/22	ND	0.06 pCi/L	
Uranium	3/9/22	ND	.0001 mg/L	
Gross Alpha	11/8/22	ND	1.8 pCi/L	
TTHM	N/A		0.080 mg/l	Residual from disinfection by-products
HAA	N/A		0.060 mg/l	Residual from disinfection by-products
Asbestos	1/5/2011	ND		

Merrill Water Department confirms that this Consumer Confidence Report has been distributed to its consumers and appropriate notices of availability have been given. Furthermore, the Merrill Water Department certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primary agency.

If you have any questions regarding these analyses or the Consumer Confidence Report, please contact Greg Matthews at Merrill Water Department at (541) 798-5808

Merrill water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Approved by:

Merrill Water Department  
Greg Matthews



Compiled and Submitted by:  
Maurene Ehlers  
Spring Street Analytical  
350 S. Spring St.  
Klamath Falls, OR 97601  
1/31/23



ND = Not Detected at the Minimum Reporting Level

[Spreadsheet](#)

Latest Chemical Results - PWS ID: 00518 ---- MERRILL WATER DEPARTMENT

Sample ID	Sample Date	Receive Date	Chemical	Source ID	Results	Current MCL	UOM
22110452-01-S	11/08/2022	11/28/2022	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.0002000	MG/L
22110452-01-S	11/08/2022	11/28/2022	2,4,5-TP	EP-A	ND	0.0500000	MG/L
22110452-01-S	11/08/2022	11/28/2022	2,4-D	EP-A	ND	0.0700000	MG/L
22110452-01-S	11/08/2022	11/28/2022	ATRAZINE	EP-A	ND	0.0030000	MG/L
22110452-01-S	11/08/2022	11/28/2022	BENZO(A)PYRENE	EP-A	ND	0.0002000	MG/L
22110452-01-S	11/08/2022	11/28/2022	BHC-GAMMA	EP-A	ND	0.0002000	MG/L
22110452-01-S	11/08/2022	11/28/2022	CARBOFURAN	EP-A	ND	0.0400000	MG/L
22110452-01-S	11/08/2022	11/28/2022	CHLORDANE	EP-A	ND	0.0020000	MG/L
22110452-01-S	11/08/2022	11/28/2022	DALAPON	EP-A	ND	0.2000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.4000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.0060000	MG/L
22110452-01-S	11/08/2022	11/28/2022	DINOSEB	EP-A	ND	0.0070000	MG/L
22110452-01-S	11/08/2022	11/28/2022	DIQUAT	EP-A	ND	0.0200000	MG/L
22110452-01-S	11/08/2022	11/28/2022	ENDOTHALL	EP-A	ND	0.1000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	ENDRIN	EP-A	ND	0.0020000	MG/L
22110452-01-S	11/08/2022	11/28/2022	ETHYLENE DIBROMIDE	EP-A	ND	0.0000500	MG/L
22110452-01-S	11/08/2022	11/28/2022	GLYPHOSATE	EP-A	ND	0.7000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	HEPTACHLOR	EP-A	ND	0.0004000	MG/L
22110452-01-S	11/08/2022	11/28/2022	HEPTACHLOR EPOXIDE	EP-A	ND	0.0002000	MG/L
22110452-01-S	11/08/2022	11/28/2022	HEXACHLOROBENZENE	EP-A	ND	0.0010000	MG/L
22110452-01-S	11/08/2022	11/28/2022	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.0500000	MG/L
22110452-01-S	11/08/2022	11/28/2022	LASSO	EP-A	ND	0.0020000	MG/L
22110452-01-S	11/08/2022	11/28/2022	METHOXYCHLOR	EP-A	ND	0.0400000	MG/L
22110452-01-S	11/08/2022	11/28/2022	OXAMYL	EP-A	ND	0.2000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	PENTACHLOROPHENOL	EP-A	ND	0.0010000	MG/L
22110452-01-S	11/08/2022	11/28/2022	PICLORAM	EP-A	ND	0.5000000	MG/L
22110452-01-S	11/08/2022	11/28/2022	SIMAZINE	EP-A	ND	0.0040000	MG/L
22110452-01-S	11/08/2022	11/28/2022	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	EP-A	ND	0.0005000	MG/L
22110452-01-S	11/08/2022	11/28/2022	TOXAPHENE	EP-A	ND	0.0030000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,1,1-TRICHLOROETHANE	EP-A	ND	0.2000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,1,2-TRICHLOROETHANE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,1-DICHLOROETHYLENE	EP-A	ND	0.0070000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,2,4-TRICHLOROBENZENE	EP-A	ND	0.0700000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,2-DICHLOROETHANE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	1,2-DICHLOROPROPANE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	BENZENE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	CARBON TETRACHLORIDE	EP-A	ND	0.0050000	MG/L

22110452-01-V	11/08/2022	11/28/2022	CHLOROBENZENE	EP-A	ND	0.1000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	CIS-1,2-DICHLOROETHYLENE	EP-A	ND	0.0700000	MG/L
22110452-01-V	11/08/2022	11/28/2022	DICHLOROMETHANE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	ETHYLBENZENE	EP-A	ND	0.7000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	O-DICHLOROBENZENE	EP-A	ND	0.6000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	P-DICHLOROBENZENE	EP-A	ND	0.0750000	MG/L
22110452-01-V	11/08/2022	11/28/2022	STYRENE	EP-A	ND	0.1000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	TETRACHLOROETHYLENE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	TOLUENE	EP-A	ND	1.0000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	TRANS-1,2-DICHLOROETHYLENE	EP-A	ND	0.1000000	MG/L
22110452-01-V	11/08/2022	11/28/2022	TRICHLOROETHYLENE	EP-A	ND	0.0050000	MG/L
22110452-01-V	11/08/2022	11/28/2022	VINYL CHLORIDE	EP-A	ND	0.0020000	MG/L
22110452-01-V	11/08/2022	11/28/2022	XYLENES, TOTAL	EP-A	ND	10.0000000	MG/L
22110838-001-R	11/08/2022	11/28/2022	GROSS ALPHA, EXCL. RADON & U	EP-A	ND	15.0000000	PCI/L
22080880-001-R	08/09/2022	09/13/2022	GROSS ALPHA, EXCL. RADON & U	EP-A	4.8700000	15.0000000	PCI/L
L7194601-R	03/09/2022	04/27/2022	COMBINED RADIUM (-226 & -228)	EP-A	ND	5.0000000	PCI/L
L7194601-R	03/09/2022	04/27/2022	COMBINED URANIUM	EP-A	ND	0.0300000	MG/L
L7194601-R	03/09/2022	04/27/2022	GROSS ALPHA, EXCL. RADON & U	EP-A	ND	15.0000000	PCI/L
N22072-I	03/09/2022	04/01/2022	NITRATE	EP-A	1.0300000	10.0000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.0002000	MG/L
2111083501A-S	11/16/2021	12/06/2021	2,4,5-TP	EP-A	ND	0.0500000	MG/L
2111083501A-S	11/16/2021	12/06/2021	2,4-D	EP-A	ND	0.0700000	MG/L
2111083501A-S	11/16/2021	12/06/2021	ATRAZINE	EP-A	ND	0.0030000	MG/L
2111083501A-S	11/16/2021	12/06/2021	BENZO(A)PYRENE	EP-A	ND	0.0002000	MG/L
2111083501A-S	11/16/2021	12/06/2021	BHC-GAMMA	EP-A	ND	0.0002000	MG/L
2111083501A-S	11/16/2021	12/06/2021	CARBOFURAN	EP-A	ND	0.0400000	MG/L
2111083501A-S	11/16/2021	12/06/2021	CHLORDANE	EP-A	ND	0.0020000	MG/L
2111083501A-S	11/16/2021	12/06/2021	DALAPON	EP-A	ND	0.2000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.4000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.0060000	MG/L
2111083501A-S	11/16/2021	12/06/2021	DINOSEB	EP-A	ND	0.0070000	MG/L
2111083501A-S	11/16/2021	12/06/2021	DIQUAT	EP-A	ND	0.0200000	MG/L
2111083501A-S	11/16/2021	12/06/2021	ENDOTHALL	EP-A	ND	0.1000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	ENDRIN	EP-A	ND	0.0020000	MG/L
2111083501A-S	11/16/2021	12/06/2021	ETHYLENE DIBROMIDE	EP-A	ND	0.0000500	MG/L
2111083501A-S	11/16/2021	12/06/2021	GLYPHOSATE	EP-A	ND	0.7000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	HEPTACHLOR	EP-A	ND	0.0004000	MG/L
2111083501A-S	11/16/2021	12/06/2021	HEPTACHLOR EPOXIDE	EP-A	ND	0.0002000	MG/L
2111083501A-S	11/16/2021	12/06/2021	HEXACHLOROBENZENE	EP-A	ND	0.0010000	MG/L
2111083501A-S	11/16/2021	12/06/2021	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.0500000	MG/L
2111083501A-S	11/16/2021	12/06/2021	LASSO	EP-A	ND	0.0020000	MG/L
2111083501A-S	11/16/2021	12/06/2021	METHOXYCHLOR	EP-A	ND	0.0400000	MG/L
2111083501A-S	11/16/2021	12/06/2021	OXAMYL	EP-A	ND	0.2000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	PENTACHLOROPHENOL	EP-A	ND	0.0010000	MG/L
2111083501A-S	11/16/2021	12/06/2021	PICLORAM	EP-A	ND	0.5000000	MG/L
2111083501A-S	11/16/2021	12/06/2021	SIMAZINE	EP-A	ND	0.0040000	MG/L

2111083501A-S	11/16/2021	12/06/2021	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	EP-A	ND	0.0005000	MG/L
2111083501A-S	11/16/2021	12/06/2021	TOXAPHENE	EP-A	ND	0.0030000	MG/L
2111083501B-I	11/16/2021	12/06/2021	ANTIMONY, TOTAL	EP-A	ND	0.0060000	MG/L
2111083501B-I	11/16/2021	12/06/2021	ARSENIC	EP-A	ND	0.0100000	MG/L
2111083501B-I	11/16/2021	12/06/2021	BARIUM	EP-A	0.0022800	2.0000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	BERYLLIUM, TOTAL	EP-A	ND	0.0040000	MG/L
2111083501B-I	11/16/2021	12/06/2021	CADMIUM	EP-A	ND	0.0050000	MG/L
2111083501B-I	11/16/2021	12/06/2021	CHROMIUM	EP-A	ND	0.1000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	CYANIDE	EP-A	ND	0.2000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	FLUORIDE	EP-A	ND	4.0000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	MERCURY	EP-A	ND	0.0020000	MG/L
2111083501B-I	11/16/2021	12/06/2021	NICKEL	EP-A	ND	0.1000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	NITRATE	EP-A	0.5620000	10.000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	NITRATE-NITRITE	EP-A	0.5620000	10.000000	MG/L
2111083501B-I	11/16/2021		NITRITE	EP-A	ND	1.0000000	MG/L
2111083501B-I	11/16/2021	12/06/2021	SELENIUM	EP-A	ND	0.0500000	MG/L
2111083501B-I	11/16/2021	12/06/2021	SODIUM	EP-A	49.400000		MG/L
2111083501B-I	11/16/2021	12/06/2021	THALLIUM, TOTAL	EP-A	ND	0.0020000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,1,1-TRICHLOROETHANE	EP-A	ND	0.2000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,1,2-TRICHLOROETHANE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,1-DICHLOROETHYLENE	EP-A	ND	0.0070000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,2,4-TRICHLOROBENZENE	EP-A	ND	0.0700000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,2-DICHLOROETHANE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	1,2-DICHLOROPROPANE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	BENZENE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	CARBON TETRACHLORIDE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	CHLOROBENZENE	EP-A	ND	0.1000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	CIS-1,2-DICHLOROETHYLENE	EP-A	ND	0.0700000	MG/L
2111083501C-V	11/16/2021	12/06/2021	DICHLOROMETHANE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	ETHYLBENZENE	EP-A	ND	0.7000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	O-DICHLOROBENZENE	EP-A	ND	0.6000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	P-DICHLOROBENZENE	EP-A	ND	0.0750000	MG/L
2111083501C-V	11/16/2021	12/06/2021	STYRENE	EP-A	ND	0.1000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	TETRACHLOROETHYLENE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	TOLUENE	EP-A	ND	1.0000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	TRANS-1,2-DICHLOROETHYLENE	EP-A	ND	0.1000000	MG/L
2111083501C-V	11/16/2021	12/06/2021	TRICHLOROETHYLENE	EP-A	ND	0.0050000	MG/L
2111083501C-V	11/16/2021	12/06/2021	VINYL CHLORIDE	EP-A	ND	0.0020000	MG/L
2111083501C-V	11/16/2021	12/06/2021	XYLENES, TOTAL	EP-A	ND	10.000000	MG/L
L7005501-R	11/16/2021	01/07/2022	COMBINED RADIUM (-226 & -228)	EP-A	ND	5.0000000	PCI/L
L7005501-R	11/16/2021	01/07/2022	COMBINED URANIUM	EP-A	ND	0.0300000	MG/L
2109043401A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0039600	1.3000000	MG/L
2109043401A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0002370	0.0150000	MG/L
2109043402A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0361000	1.3000000	MG/L
2109043402A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0001660	0.0150000	MG/L
2109043403A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0027800	1.3000000	MG/L

2109043403A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0003160	0.0150000	MG/L
2109043404A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0005560	1.3000000	MG/L
2109043404A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0005250	0.0150000	MG/L
2109043405A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0007680	1.3000000	MG/L
2109043405A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0001280	0.0150000	MG/L
2109043406A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0053600	1.3000000	MG/L
2109043406A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0002290	0.0150000	MG/L
2109043407A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0005240	1.3000000	MG/L
2109043407A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0002060	0.0150000	MG/L
2109043408A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0019800	1.3000000	MG/L
2109043408A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0003610	0.0150000	MG/L
2109043409A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0027500	1.3000000	MG/L
2109043409A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0005190	0.0150000	MG/L
2109043410A	09/09/2021	09/23/2021	COPPER	DIST-A	0.0018100	1.3000000	MG/L
2109043410A	09/09/2021	09/23/2021	LEAD	DIST-A	0.0003710	0.0150000	MG/L
N21289-I	07/19/2021	08/02/2021	NITRATE	EP-A	0.1600000	10.000000	MG/L
N20292-I	08/17/2020	09/08/2020	NITRATE	EP-A	0.9900000	10.000000	MG/L
1912081201-S	12/17/2019	01/02/2020	1,2-DIBROMO-3-CHLOROPROPANE	EP-A	ND	0.0002000	MG/L
1912081201-S	12/17/2019	01/02/2020	2,4,5-TP	EP-A	ND	0.0500000	MG/L
1912081201-S	12/17/2019	01/02/2020	2,4-D	EP-A	ND	0.0700000	MG/L
1912081201-S	12/17/2019	01/02/2020	ATRAZINE	EP-A	ND	0.0030000	MG/L
1912081201-S	12/17/2019	01/02/2020	BENZO(A)PYRENE	EP-A	ND	0.0002000	MG/L
1912081201-S	12/17/2019	01/02/2020	BHC-GAMMA	EP-A	ND	0.0002000	MG/L
1912081201-S	12/17/2019	01/02/2020	CARBOFURAN	EP-A	ND	0.0400000	MG/L
1912081201-S	12/17/2019	01/02/2020	CHLORDANE	EP-A	ND	0.0020000	MG/L
1912081201-S	12/17/2019	01/02/2020	DALAPON	EP-A	ND	0.2000000	MG/L
1912081201-S	12/17/2019	01/02/2020	DI(2-ETHYLHEXYL) ADIPATE	EP-A	ND	0.4000000	MG/L
1912081201-S	12/17/2019	01/02/2020	DI(2-ETHYLHEXYL) PHTHALATE	EP-A	ND	0.0060000	MG/L
1912081201-S	12/17/2019	01/02/2020	DINOSEB	EP-A	ND	0.0070000	MG/L
1912081201-S	12/17/2019	01/02/2020	DIQUAT	EP-A	ND	0.0200000	MG/L
1912081201-S	12/17/2019	01/02/2020	ENDOTHALL	EP-A	ND	0.1000000	MG/L
1912081201-S	12/17/2019	01/02/2020	ENDRIN	EP-A	ND	0.0020000	MG/L
1912081201-S	12/17/2019	01/02/2020	ETHYLENE DIBROMIDE	EP-A	ND	0.0000500	MG/L
1912081201-S	12/17/2019	01/02/2020	GLYPHOSATE	EP-A	ND	0.7000000	MG/L
1912081201-S	12/17/2019	01/02/2020	HEPTACHLOR	EP-A	ND	0.0004000	MG/L
1912081201-S	12/17/2019	01/02/2020	HEPTACHLOR EPOXIDE	EP-A	ND	0.0002000	MG/L
1912081201-S	12/17/2019	01/02/2020	HEXACHLOROBENZENE	EP-A	ND	0.0010000	MG/L
1912081201-S	12/17/2019	01/02/2020	HEXACHLOROCYCLOPENTADIENE	EP-A	ND	0.0500000	MG/L
1912081201-S	12/17/2019	01/02/2020	LASSO	EP-A	ND	0.0020000	MG/L
1912081201-S	12/17/2019	01/02/2020	METHOXYCHLOR	EP-A	ND	0.0400000	MG/L
1912081201-S	12/17/2019	01/02/2020	OXAMYL	EP-A	ND	0.2000000	MG/L
1912081201-S	12/17/2019	01/02/2020	PENTACHLOROPHENOL	EP-A	ND	0.0010000	MG/L
1912081201-S	12/17/2019	01/02/2020	PICLORAM	EP-A	ND	0.5000000	MG/L
1912081201-S	12/17/2019	01/02/2020	SIMAZINE	EP-A	ND	0.0040000	MG/L
1912081201-S	12/17/2019	01/02/2020	TOTAL POLYCHLORINATED BIPHENYLS (PCB)	EP-A	ND	0.0005000	MG/L
1912081201-S	12/17/2019	01/02/2020	TOXAPHENE	EP-A	ND	0.0030000	MG/L